

HALEY & ALDRICH, INC. One Arizona Center 400 E. Van Buren St., Suite 545 Phoenix, AZ 85004 602.760.2450

12 August 2024 File No. 0211090-000

Associated Electric Cooperative, Inc. 2814 South Golden Avenue P.O. Box 754 Springfield, Missouri 65801-0754

Attention: Jenny Jones – Manager, Land and Water Resources

Subject: Assessment Monitoring Program February 2024 Sampling Event

Statistically Significant Level Notification New Madrid Power Plant – Pond 003

Dear Ms. Jones:

Associated Electric Cooperative, Inc. (AECI) has implemented the U.S. Environmental Protection Agency Federal Coal Combustion Residuals Rule (Title 40 Code of Federal Regulations [40 CFR] §§ 257 and 261) effective 19 October 2015, along with subsequent revisions, for the New Madrid Power Plant in Marston, Missouri. AECI provided Haley & Aldrich, Inc. with groundwater monitoring data collected from the Pond 003 groundwater monitoring system that meet the requirements of 40 CFR §§ 257.91 and 257.93. This memorandum documents the results of statistical tests conducted to determine if Appendix IV groundwater monitoring constituents detected in wells downgradient of Pond 003 are present at a statistically significant level (SSL) above groundwater protection standards (GWPS) consistent with the requirements in 40 CFR § 257.95.

Results of the statistical analyses completed on 12 July 2024 of the February 2024 assessment monitoring sampling event data for each analyte/well combination indicate a SSL above GWPS for selenium at monitoring well P-1. Consistent with statistical analyses completed for previous assessment monitoring events, molybdenum was indicated as a SSL at monitoring wells MW-7, MW-8, MW-9, P-2, P-3, and P-5 for the February 2024 event.

Sincerely yours,

HALEY & ALDRICH, INC.

Steve Putrich, P.E. Project Principal

Mark Nicholls, P.G. Lead Hydrogeologist